



150001283373



(2015)国认监认字(531)号



中国认可
国际互认
检测
TESTING
CNAS L1449

检 验 报 告

TEST REPORT

报告编号: FH2017BW0302



样品名称: 井干式木刻楞墙体

Sample Name

委托单位: 满洲里凯润木业有限公司

Applicant

检验类别: 委托检验

Test Type

国家建筑防火产品安全质量监督检验中心

National Center for Safety Quality Supervision and Testing of Fire-proof Building Products



国家建筑防火产品安全质量监督检验中心

检 验 报 告 (TEST REPORT)



报告编号№: FH2017BW0302

第1页, 共3页

委托单位 Applicant	满洲里凯润木业有限公司	检验类别 Test Type	委托检验
受检单位 Inspected Entity	满洲里凯润木业有限公司	委托日期 Consign Date	2017年09月21日
工程名称及使用部位 Engineering Name and Application Part	——	来样日期 Accept Date	2017年09月21日
样品名称 Sample Name	井干式木刻楞墙体	样品数量 Sample Quantity	2.25m ²
型号/规格 Type/Specification	1500mm×1500mm×140mm	样品等级 Grade	——
生产单位 Manufacturer	满洲里凯润木业有限公司	样品状态 Sample State	板状
生产日期/批号 Production Date/Lot №	——	商标 Trade Mark	——
检验依据 Ref Documents	GB/T 13475-2008 《绝热 稳态传热性质的测定 标定和保护热箱法》		
检验项目 Test Item	传热系数		
检验结论 Test Conclusion	该样品经检验, 传热系数检验结果见第2页。  签发日期: 2017年10月16日 Issued by(Stamp)		
附注 Remarks	1. 本检验结果仅对来样负责; 2. 试验墙体厚度为140mm。		

批 准:
Approved by:

审 核:
Inspected by:

主 检:
Tested by:

国家建筑防火产品安全质量监督检验中心

检 验 报 告 (TEST REPORT)

报告编号№: FH2017BW0302

第2页, 共3页

序号	检验项目	标准要求	检验结果	单项判定
1	传热系数, W/ (m ² · K)	—	0.69	—

检测地址: 北京市房山区窦店镇亚新路17号;
联系电话: 4000330789、010-60350462-8053。

(本页以下空白)



国家建筑防火产品安全质量监督检验中心

检 验 报 告 (TEST REPORT)

报告编号№: FH2017BW0302

第3页, 共3页



***** 结 束 *****

注 意 事 项

NOTICE

1.报告无“检验检测专用章”或检验单位公章、骑缝章无效。

Test report is invalid without the "special seal for test report" or that of test department and perforated rider stamp on it.

2.复制报告未重新加盖“检验检测专用章”或检验单位公章无效。

Duplication of test report is invalid without the "special seal for test report" or that of test department re-stamped on it.

3.报告无主检、审核、批准签字无效。

Test report is invalid without the signatures of the persons for chief test, verification and approval.

4.报告涂改无效。


Test report is invalid if altered.

5.对检验报告若有异议，应于收到报告之日起十五日内向检验单位提出。

Any dissidence about the test report should be brought forward to the test department within 15 days from the date of receiving the test report.

6.一般情况，委托检验仅对来样负责。

In general, for entrusted tests the responsibilities are undertaken for the delivered samples only.



路线备注：沿阜石路高架向西行驶，见金顶西街出口进入辅路，金安桥下右转，第二个丁字路口（第一个红绿灯）右转，直行 600 米路北。



地址：北京市石景山区金顶北路69号(100041)

Add: No. 69 Jin Ding North Road, Shijingshan District, Beijing, China 100041

网址(Web): www.bmtbj.cn

电话(Tel): 010-88724984 88749821

传真(Fax): 010-88715189

客服热线: 400-0330-789